

RESA TERMICA RISCALDAMENTO

Test report
for the determination of the heating capacity
of hot surface for rooms

heating ceiling

Type: Pannello Radiante in Cartongesso
Soffitto / parete: PRC 5.0

closed heating ceiling,
PEX-tubes (8 x 1mm) integrated in plasterboard panel
distance between the tubes: 50mm

Indecal s.r.l.
I – 70024 Gravina in Puglia (BA)

Test report

No.: DF10 H26.2856

heating capacity: 72 W/m² (Δt : 15K)

(referring to the active area: 7,20m²)



This test report consists of 6 pages and it may be reproduced only in its integral form.
The results of the test refer only to the test samples.

The HVAC Institute, Lehrstuhl für Heiz- und Raumlufttechnik (LHR), is from DAR accredited according to ISO/IEC 17025 and is from DINCERTCO recognised as an independent test laboratory. Further on the Institute is also an accredited inspection body according to EN 45004.



test report no. DF10 H26.2856

page 4/6

Typ: Pannello Radiante in Cartongesso
 soffitto/parete: PRC 5.0

